



Microbac Laboratories, Inc., Sayre Division
CERTIFICATE OF ANALYSIS

S1F0449

GST BOCES/Elmira

Project Name: Drinking Water

Alex Frame
 459 Philo Road
 Elmira, NY 14903

Project / PO Number: N/A
 Received: 06/10/2021
 Reported: 07/30/2021

Analytical Testing Parameters

Client Sample ID: CSE - 1	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:40
Lab Sample ID: S1F0449-01	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0015	0.015 AL	0.0015	mg/L	D	07/13/21 1501	07/14/21 1624	LLW

Client Sample ID: CSE - 2	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:41
Lab Sample ID: S1F0449-02	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1533	LLW

Client Sample ID: CSE - 3	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:41
Lab Sample ID: S1F0449-03	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1535	LLW

Client Sample ID: CSE - 4	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:42
Lab Sample ID: S1F0449-04	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1537	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 5	Sample Matrix: Drinking Water	Collected By: Alex Frame
Lab Sample ID: S1F0449-05		Collection Date: 06/10/2021 4:42

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1538	LLW

Client Sample ID: CSE - 6	Sample Matrix: Drinking Water	Collected By: Alex Frame
Lab Sample ID: S1F0449-06		Collection Date: 06/10/2021 4:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0219	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1540	LLW

Client Sample ID: CSE - 7	Sample Matrix: Drinking Water	Collected By: Alex Frame
Lab Sample ID: S1F0449-07		Collection Date: 06/10/2021 4:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1546	LLW

Client Sample ID: CSE - 8	Sample Matrix: Drinking Water	Collected By: Alex Frame
Lab Sample ID: S1F0449-08		Collection Date: 06/10/2021 4:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1548	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 9	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:46
Lab Sample ID: S1F0449-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0162	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1549	LLW

Client Sample ID: CSE - 10	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:46
Lab Sample ID: S1F0449-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1551	LLW

Client Sample ID: CSE - 11	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:47
Lab Sample ID: S1F0449-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0155	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1553	LLW

Client Sample ID: CSE - 12	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:48
Lab Sample ID: S1F0449-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1557	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 13	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:48
Lab Sample ID: S1F0449-13	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0066	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1559	LLW

Client Sample ID: CSE - 14	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:48
Lab Sample ID: S1F0449-14	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0049	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1600	LLW

Client Sample ID: CSE - 15	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:49
Lab Sample ID: S1F0449-15	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0371	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1602	LLW

Client Sample ID: CSE - 16	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:49
Lab Sample ID: S1F0449-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1608	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 17	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:49
Lab Sample ID: S1F0449-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0325	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1610	LLW

Client Sample ID: CSE - 18	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:55
Lab Sample ID: S1F0449-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0067	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1611	LLW

Client Sample ID: CSE - 19	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:56
Lab Sample ID: S1F0449-19	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1501	07/13/21 1613	LLW

Client Sample ID: CSE - 20	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:57
Lab Sample ID: S1F0449-20	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0015	0.015 AL	0.0015	mg/L	D	07/13/21 1501	07/14/21 1629	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 21	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:57
Lab Sample ID: S1F0449-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1624	LLW

Client Sample ID: CSE - 22	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:58
Lab Sample ID: S1F0449-22	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0196	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1630	LLW

Client Sample ID: CSE - 23	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:58
Lab Sample ID: S1F0449-23	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1632	LLW

Client Sample ID: CSE - 24	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:53
Lab Sample ID: S1F0449-24	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.015 AL	0.0031	mg/L	D	07/13/21 1503	07/15/21 1206	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 25	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:53
Lab Sample ID: S1F0449-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0015	0.015 AL	0.0015	mg/L	D	07/13/21 1503	07/15/21 1208	LLW

Client Sample ID: CSE - 26	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:52
Lab Sample ID: S1F0449-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.015 AL	0.0015	mg/L	D	07/13/21 1503	07/15/21 1211	LLW

Client Sample ID: CSE - 27	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:52
Lab Sample ID: S1F0449-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0031	0.015 AL	0.0031	mg/L	D	07/13/21 1503	07/15/21 1220	LLW

Client Sample ID: CSE - 28	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:52
Lab Sample ID: S1F0449-28	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0179	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1644	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 29	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 4:59
Lab Sample ID: S1F0449-29	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1646	LLW

Client Sample ID: CSE - 30	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:00
Lab Sample ID: S1F0449-30	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1648	LLW

Client Sample ID: CSE - 31	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:01
Lab Sample ID: S1F0449-31	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1650	LLW

Client Sample ID: CSE - 32	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:01
Lab Sample ID: S1F0449-32	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1654	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 33	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:02
Lab Sample ID: S1F0449-33	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1655	LLW

Client Sample ID: CSE - 34	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:02
Lab Sample ID: S1F0449-34	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1657	LLW

Client Sample ID: CSE - 35	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:03
Lab Sample ID: S1F0449-35	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.015 AL	0.0010	mg/L		07/13/21 1503	07/13/21 1659	LLW

Client Sample ID: CSE - 36	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:03
Lab Sample ID: S1F0449-36	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0015	mg/L	D	07/13/21 1503	07/14/21 1743	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 37	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:04
Lab Sample ID: S1F0449-37	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0061	0.015 AL	0.0061	mg/L	D	07/13/21 1503	07/15/21 1241	LLW

Client Sample ID: CSE - 38	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:05
Lab Sample ID: S1F0449-38	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0031	0.015 AL	0.0031	mg/L	D	07/13/21 1503	07/15/21 1228	LLW

Client Sample ID: CSE - 39	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:05
Lab Sample ID: S1F0449-39	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0053	0.015 AL	0.0015	mg/L	D	07/13/21 1503	07/14/21 1803	LLW

Client Sample ID: CSE - 40	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:06
Lab Sample ID: S1F0449-40	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.015 AL	0.0015	mg/L	D	07/13/21 1503	07/15/21 1229	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 41	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:07
Lab Sample ID: S1F0449-41	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1721	LLW

Client Sample ID: CSE - 42	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:08
Lab Sample ID: S1F0449-42	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1727	LLW

Client Sample ID: CSE - 43	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:09
Lab Sample ID: S1F0449-43	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1728	LLW

Client Sample ID: CSE - 44	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:10
Lab Sample ID: S1F0449-44	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1730	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 45	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:10
Lab Sample ID: S1F0449-45	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0183	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1732	LLW

Client Sample ID: CSE - 46	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:11
Lab Sample ID: S1F0449-46	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1734	LLW

Client Sample ID: CSE - 47	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:11
Lab Sample ID: S1F0449-47	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1739	LLW

Client Sample ID: CSE - 48	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:14
Lab Sample ID: S1F0449-48	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1741	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 49	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:14
Lab Sample ID: S1F0449-49	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1743	LLW

Client Sample ID: CSE - 50	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:14
Lab Sample ID: S1F0449-50	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1745	LLW

Client Sample ID: CSE - 51	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:15
Lab Sample ID: S1F0449-51	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1747	LLW

Client Sample ID: CSE - 52	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:15
Lab Sample ID: S1F0449-52	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1750	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 53	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:16
Lab Sample ID: S1F0449-53	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1752	LLW

Client Sample ID: CSE - 54	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:16
Lab Sample ID: S1F0449-54	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0042	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1754	LLW

Client Sample ID: CSE - 55	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:17
Lab Sample ID: S1F0449-55	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1756	LLW

Client Sample ID: CSE - 56	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:18
Lab Sample ID: S1F0449-56	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1802	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 57	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:20
Lab Sample ID: S1F0449-57	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1803	LLW

Client Sample ID: CSE - 58	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:20
Lab Sample ID: S1F0449-58	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1805	LLW

Client Sample ID: CSE - 59	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:23
Lab Sample ID: S1F0449-59	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1807	LLW

Client Sample ID: CSE - 60	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:24
Lab Sample ID: S1F0449-60	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		07/13/21 1510	07/13/21 1809	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Client Sample ID: CSE - 61	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:25
Lab Sample ID: S1F0449-61	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0064	0.015 AL	0.0010	mg/L		07/13/21 1511	07/13/21 1859	LLW

Client Sample ID: CSE - 62	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:26
Lab Sample ID: S1F0449-62	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.015 AL	0.0010	mg/L		07/13/21 1511	07/13/21 1901	LLW

Client Sample ID: CSE - 63	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 5:26
Lab Sample ID: S1F0449-63	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.015 AL	0.0010	mg/L		07/13/21 1511	07/13/21 1903	LLW

Client Sample ID: CSBG - 1	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/10/2021 8:35
Lab Sample ID: S1F0449-64	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		07/13/21 1511	07/13/21 1905	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0449

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- MDL: Minimum Detection Limit
- mg/L: Milligrams per Liter
- NYVOA: New York DOH Part 5 Public Water System MCLs
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.***

Reviewed and Approved By:

Renee Lantz
Customer Relationship Specialist
Reported: 07/30/2021 16:34

Microbac Laboratories, Inc.

2369 Elmira Street | Sayre, PA 18840 | 570-888-0169 p | www.microbac.com

CHAIN OF CUSTODY RECORD

3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number: **607-753-3403**
 Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time

Invoice Address

Lab Report Address

Temperature Upon Receipt (°C)
Therm ID

Routine (5 to 7 business days)
 RUSH* (notify lab)

Client Name: Campbell Savona CSD
 Address: 8455 County Rt 125
 City, State, Zip: Campbell NY, 14821-9518

Client Name: Alex Frame
 Address: 459 Philo Rd
 City, State, Zip: Elmira NY, 14903

Holding Time

Report Type

Contact: John Machuga
 Telephone No.: 607-527-9800

Contact: Alex Frame
 Telephone No.: 607-739-3581 x 1476

Samples Received on Ice? Yes No **N/A**

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Report via: Mail e-mail (address) **AFrame@gstbores.org** Send Invoice via: **AFrame@gstbores.org**

Project: 2021 10 NYCRR Subpart 67.4

Custody Seals Intact? Yes No **N/A**

Compliance Monitoring? Yes No
 () Agency/Program

Location: Campbell Savona Elementary PO No.:

Sampler Signature: *Alex Frame*

Sampler Phone No.: **607-739-3581 x 1476**

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

Matrix: **DW 6**

Matrix: **DW 6**

Requested Analysis

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (U) Unpreserved

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (U) Unpreserved

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis



S 1 F 0 4 4 9

GST BOCES/Elmira

PM: Renee Lantz

Additional A

*MD in DW
Pres 8:00*

Preservative Types

Matrix

No. of Containers

Date Collected

Time Collected

Client Sample ID

CSE-1
CSE-2
CSE-3
CSE-4
CSE-5
CSE-6
CSE-7
CSE-8
CSE-9
CSE-10

Possible Hazard Identification Comments

Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature)

Date/Time

8:00

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

8:00

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

8:00

Received By (signature)

Date/Time

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number
Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address: GST BOCES, 459 Philo Rd, Elmira NY, 14903, Alex Frame, 607-739-3581 x 1476, Alex Frame, 607-739-3581 x 1476, 2021 10 NYCRR Subpart 67.4

Invoice Address: Client Name: Campbell Savona CSD, Address: 8455 County Rt 125, City, State, Zip: Campbell NY, 14821-9518, Contact: John Machuga, Telephone No.: 607-527-9800, Send Invoice via: aframe@gstbores.org

Turnaround Time: Routine (5 to 7 business days) [X], RUSH* (notify lab) [], Results Only [], Level 1 [], Level 2 [], Level 3 [], Level 4 [], EDD [], Mail [], Fax [], e-mail (address) Jmachuga@csbsd.org

Temperature Upon Receipt (°C) Therm ID: Holding Time: Samples Received on Ice? Yes [No] N/A, Custody Seals Intact? Yes [No] N/A, Compliance Monitoring? [X] Yes [] No, Agency/Program: 607-739-3581 X 1476

Sampled by (PRINT): Alex Frame, Sampler Signature: [Signature], Sampler Phone No.: 607-739-3581 X 1476

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved



GST BOCES/Elmira
PM: Renee Lantz

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types	Additional
CSE-11		6/10/21	4:47	1	DW	U	
CSE-12			4:48				
CSE-13			4:48				
CSE-14			4:48				
CSE-15			4:49				
CSE-16			4:49				
CSE-17			4:49				
CSE-18			4:55				
CSE-19			4:56				
CSE-20			4:57				

Possible Hazard Identification: [] Hazardous [] Non-Hazardous [] Radioactive [] Sample Disposition: [] Dispose as appropriate [] Return [] Archive

Comments: Relinquished By (signature) [Signature], Date/Time: 6/10/21 8:06, Received By (signature) [Signature], Date/Time: 6/10/21 8:06

CHAIN OF CUSTODY RECORD

MicroBAC 3821 Buck Dr., Confland, NY 13045 | 607-753-3403 p | 607-753-3415 f

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address: Invoice Address: Turnaround Time: Routine (5 to 7 business days) RUSH* (notify lab)

Client Name: GST-BOCES Client Name: Campbell Savona CSD

Address: 459 Philo Rd Address: 8455 County Rt 125

City, State, Zip: Elmira NY, 14903 City, State, Zip: Campbell NY, 14821-9518

Contact: Alex Frame Contact: John Machuga

Telephone No.: 607-739-3581 x 1476 Telephone No.: 607-527-9800

Send Report via: Mail e-mail (address) alexframe@gstboes.org Send Invoice via: Mail e-mail (address) jmachuga@csbsd.org

Project: 2021 10 NYCRR Subpart 67.4 Location: Campbell Savona Elementary PO No.:
 Sampler Signature: Alex Frame Sampler Phone No.: 607-739-3581 x 1476

Temperature Upon Receipt (°C) Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Compliance Monitoring? Yes No

() Agency/Program

Requested Analysis

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Type	Sample Disposition
CSE-21		6/10/21	4:57	1	DW	M	Lead in Pb
CSE-22			4:58				
CSE-23			4:58				
CSE-24			4:53				
CSE-25			4:53				
CSE-26			4:57				
CSE-27			4:57				
CSE-28			4:57				
CSE-29			4:59				
CSE-30			5:00				

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive

Comments: Dispose as appropriate Return Archive


Relinquished By (signature): Alex Frame Date/Time: 6/10/21

Relinquished By (signature): [Signature] Date/Time: 8:06

Received By (signature): [Signature] Date/Time: 6/10/21

Received By (signature): [Signature] Date/Time: 6/10/21

Additional: Lead in Pb



GST-BOCES/Elmira
PM: Renee Lantz

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time

Invoice Address

Temperature Upon Receipt (°C)
Therm ID

Routine (5 to 7 business days)
 RUSH* (notify lab)

Client Name: Campbell Savona CSD

Holding Time

Address: 8455 County Rt 125

Samples Received on Ice? Yes No **N/A**

(needed by)

City, State, Zip: Campbell NY, 14821-9518

Custody Seals Intact? Yes No **N/A**

Report Type

Contact: John Machuga

Level 2 Level 3 Level 4 EDD

Telephone No.: 607-527-9800

Compliance Monitoring? Yes No

Send Invoice via: **cfham@jstboes.org**

Telephone No.: 607-527-9800

() Agency/Program


Location: Campbell Savona Elementary

PO No.:

Sampler Phone No.: **607-739-3581 x 1476**

Sampler Signature: *ASZ*

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (Specify)
Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved



Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Type	Additional
	CSE-31	6/10/21	5:01	1	DW	M	
	CSE-32		5:01				
	CSE-33		5:01				
	CSE-34		5:02				
	CSE-35		5:03				
	CSE-36		5:03				
	CSE-37		5:04				
	CSE-38		5:05				
	CSE-39		5:05				
	CSE-40		5:06				

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive Sample Disposition: Dispose as appropriate Return Archive

Comments

Relinquished By (signature) *[Signature]* Date/Time 6/10/21 8:06
 Relinquished By (signature) *[Signature]* Date/Time
 Relinquished By (signature) *[Signature]* Date/Time
 Received By (signature) *[Signature]* Date/Time
 Received By (signature) *[Signature]* Date/Time
 Received By (signature) *[Signature]* Date/Time

CHAIN OF CUSTODY RECORD

3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number
Instructions on Back

TO BE COMPLETED BY MICROBAC

Lab Report Address: Invoice Address: Client Name: Campbell Savona CSD
 Address: 459 Philo Rd 8455 County Rt 125
 City, State, Zip: Elmira NY, 14903 Campbell NY, 14821-9518
 Contact: Alex Frame John Machuga
 Telephone No.: 607-739-3581 x 1476 Telephone No.: 607-527-9800
 Send Report via: [] Mail [] Fax [] e-mail (address) af@microbacs.org Send Invoice via:
 Project: 2021 10 NYCRR Subpart 67.4 Location: Campbell Savona Elementary PO No.:
 Turnaround Time: Routine (5 to 7 business days) (needed by)
 RUSH* (notify lab)
 Temperature Upon Receipt (°C)
 Therm ID
 Holding Time
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A
 Results Only [] Level 1 [] Level 2 [] Level 3 [] Level 4 [] EDD
 [X] Mail [] Fax [X] e-mail (address) Jmachuga@cssd.org
 Compliance Monitoring? Yes [] No
 () Agency/Program
 Sampler Phone No.: 607-739-3581 x1476

Sampled by (PRINT): Alex frame Signature: [Signature]
 Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved
 REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Type	Additional Notes
CSE-41		6/10/21	5:07	1	DW	G	M	
CSE-42			5:08					
CSE-43			5:09					
CSE-44			5:10					
CSE-45			5:10					
CSE-46			5:11					
CSE-47			5:11					
CSE-48			5:14					
CSE-49			5:14					
CSE-50			5:14					

Possible Hazard Identification: [] Hazardous [] Non-Hazardous [] Radioactive [] Disposition as appropriate [] Return [] Archive
 Comments: Lead in DW
 Relinquished By (signature): [Signature] Date/Time: 6/10/21
 Relinquished By (signature): [Signature] Date/Time: 6/10/21
 Relinquished By (signature): [Signature] Date/Time: 6/10/21
 Received By (signature): [Signature] Date/Time: 6/10/21
 Received By (signature): [Signature] Date/Time: 6/10/21
 Received By (signature): [Signature] Date/Time: 6/10/21
 Date/Time: 6/10/21 0806
 Page 5 of 7



GST BOCES/Elmira
PM: Renee Lantz

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number

Instructions on Back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)
Therm ID

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)

Invoice Address
Client Name: Campbell Savona CSD
Address: 8455 County Rt 125
City, State, Zip: Campbell NY, 14821-9518
Contact: John Machuga
Telephone No.: 607-527-9800

Lab Report Address
Client Name: GST BOCES
Address: 459 Philo Rd
City, State, Zip: Elmira NY, 14903
Contact: Alex Frane
Telephone No.: 607-739-3581 x 1476

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A


Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Report via: Mail e-mail (address) afrane@gstbooces.org e-mail (address) JMachuga@campbellcso.org
Project: 2021 10 NYCRR Subpart 67.4 Location: Campbell Savona Elementary PO No.:
Compliance Monitoring? Yes No CSCSD.org
() Agency/Program

Sampled by (PRINT): Alex Frane Sampler Signature: [Signature] Sampler Phone No.: 607-739-3581 x 1476

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HINO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS



Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Type	Additional
	CSE-51	6/10/21	5:15	1	DW	DW	
	CSE-52		5:15				
	CSE-53		5:16				
	CSE-54		5:16				
	CSE-55		5:17				
	CSE-56		5:18				
	CSE-57		5:20				
	CSE-58		5:20				
	CSE-59		5:23				
	CSE-60		5:24				

Possible Hazard Identification
Comments

Hazardous Non-Hazardous Radioactive Dispose as appropriate Return Archive

Relinquished By (signature) [Signature] Date/Time 6/10/21
Relinquished By (signature) [Signature] Date/Time 8:06
Relinquished By (signature) [Signature] Date/Time 6/10/21 0800

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address: GST BOCES, 459 Philo Rd, Elmira NY, 14903
 Invoice Address: Client Name: Campbell Savona CSD, Address: 8455 County Rt 125, Campbell NY, 14821-9518
 Turnaround Time: Routine (5 to 7 business days) RUSH* (notify lab)

Temperature Upon Receipt (°C):
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Report Type: (needed by)
 Results Only Level 1 Level 2 Level 3 Level 4 EDD
 Mail Fax e-mail (address) *Jmachuga@gsstboes.csd*
 Compliance Monitoring? Yes No
 Agency/Program

Send Report via: Mail e-mail (address) *afrawm@gsstboes.csd* Send Invoice via:
 Project: 2021 10 NYCRR Subpart 67.4 Location: Campbell Savona Elementary PO No.:
 Sampler Signature: *Alex Frann* Sampler Phone No.: *607-739-3581 X1476*

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved
 REQUESTED ANALYSIS



GST BOCES/Elmira
 PM: Renee Lantz

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Additional
	<i>CSE-61</i>	<i>6/10/21</i>	<i>5:25</i>	<i>1</i>	<i>DW</i>	<i>6</i>	<i>NU</i>	<i>lead in DW</i>
	<i>CSE-62</i>		<i>5:26</i>					
	<i>CSE-63</i>		<i>5:26</i>					
	<i>CSB6-1</i>		<i>5:35</i>					

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive
 Comments: Sample Disposition: Dispose as appropriate Return Archive
 Relinquished By (signature): *[Signature]* Date/Time: *6/10/21*
 Relinquished By (signature): *[Signature]* Date/Time: *6/10/21*
 Relinquished By (signature): *[Signature]* Date/Time: *6/10/21*
 Received By (signature): *[Signature]* Date/Time: *6/10/21*
 Received By (signature): *[Signature]* Date/Time: *6/10/21*
 Received By (signature): *[Signature]* Date/Time: *6/10/21*