



Microbac Laboratories, Inc., Sayre Division
CERTIFICATE OF ANALYSIS

S1F0450

GST BOCES/Elmira

Project Name: Campbell Savona HS/MS

Alex Frame
 459 Philo Road
 Elmira, NY 14903

Project / PO Number: N/A
 Received: 06/11/2021
 Reported: 07/25/2021

Analytical Testing Parameters

Client Sample ID: CSHSMS - 1	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:22
Lab Sample ID: S1F0450-01	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1334	LLW

Client Sample ID: CSHSMS - 4	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:21
Lab Sample ID: S1F0450-02	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1339	LLW

Client Sample ID: CSHSMS - 5	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:25
Lab Sample ID: S1F0450-03	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1341	LLW

Client Sample ID: CSHSMS - 6	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:26
Lab Sample ID: S1F0450-04	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1343	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 7	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:26
Lab Sample ID: S1F0450-05	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1345	LLW

Client Sample ID: CSHSMS - 8	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:27
Lab Sample ID: S1F0450-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1347	LLW

Client Sample ID: CSHSMS - 9	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:28
Lab Sample ID: S1F0450-07	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1352	LLW

Client Sample ID: CSHSMS - 10	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:29
Lab Sample ID: S1F0450-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0444	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1354	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 11	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:30
Lab Sample ID: S1F0450-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0252	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1356	LLW

Client Sample ID: CSHSMS - 12	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:30
Lab Sample ID: S1F0450-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0256	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1358	LLW

Client Sample ID: CSHSMS - 13	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:31
Lab Sample ID: S1F0450-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0089	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1359	LLW

Client Sample ID: CSHSMS - 14	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:31
Lab Sample ID: S1F0450-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1403	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 15	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:35
Lab Sample ID: S1F0450-13	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1405	LLW

Client Sample ID: CSHSMS - 16	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:35
Lab Sample ID: S1F0450-14	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1407	LLW

Client Sample ID: CSHSMS - 17	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:37
Lab Sample ID: S1F0450-15	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1409	LLW

Client Sample ID: CSHSMS - 18	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:19
Lab Sample ID: S1F0450-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1414	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 19	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:39
Lab Sample ID: S1F0450-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1416	LLW

Client Sample ID: CSHSMS - 20	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:39
Lab Sample ID: S1F0450-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1418	LLW

Client Sample ID: CSHSMS - 21	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:39
Lab Sample ID: S1F0450-19	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0122	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1420	LLW

Client Sample ID: CSHSMS - 22	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:08
Lab Sample ID: S1F0450-20	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		07/13/21 1226	07/13/21 1421	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 23	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:09
Lab Sample ID: S1F0450-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0196	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1431	LLW

Client Sample ID: CSHSMS - 24	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:09
Lab Sample ID: S1F0450-22	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0042	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1436	LLW

Client Sample ID: CSHSMS - 25	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:09
Lab Sample ID: S1F0450-23	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1438	LLW

Client Sample ID: CSHSMS - 26	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:11
Lab Sample ID: S1F0450-24	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0051	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1440	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 27	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:12
Lab Sample ID: S1F0450-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1442	LLW

Client Sample ID: CSHSMS - 28	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:12
Lab Sample ID: S1F0450-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0083	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1443	LLW

Client Sample ID: CSHSMS - 29	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:12
Lab Sample ID: S1F0450-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1449	LLW

Client Sample ID: CSHSMS - 30	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:16
Lab Sample ID: S1F0450-28	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1451	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 31	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:14
Lab Sample ID: S1F0450-29	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1453	LLW

Client Sample ID: CSHSMS - 32	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:15
Lab Sample ID: S1F0450-30	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1454	LLW

Client Sample ID: CSHSMS - 33	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:44
Lab Sample ID: S1F0450-31	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1456	LLW

Client Sample ID: CSHSMS - 34	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:44
Lab Sample ID: S1F0450-32	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0031	0.015 AL	0.0031	mg/L	D	07/13/21 1228	07/15/21 1202	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 35	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:55
Lab Sample ID: S1F0450-33	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0233	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1502	LLW

Client Sample ID: CSHSMS - 36	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:56
Lab Sample ID: S1F0450-34	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1504	LLW

Client Sample ID: CSHSMS - 37	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:58
Lab Sample ID: S1F0450-35	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1505	LLW

Client Sample ID: CSHSMS - 38	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:57
Lab Sample ID: S1F0450-36	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1511	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 39	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:47
Lab Sample ID: S1F0450-37	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1513	LLW

Client Sample ID: CSHSMS - 40	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:48
Lab Sample ID: S1F0450-38	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0085	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1515	LLW

Client Sample ID: CSHSMS - 41	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:50
Lab Sample ID: S1F0450-39	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1516	LLW

Client Sample ID: CSHSMS - 42	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:50
Lab Sample ID: S1F0450-40	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0318	0.015 AL	0.0010	mg/L		07/13/21 1228	07/13/21 1518	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 43	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:51
Lab Sample ID: S1F0450-41	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0130	0.015 AL	0.0010	mg/L		07/13/21 1513	07/13/21 1926	LLW

Client Sample ID: CSHSMS - 44	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:52
Lab Sample ID: S1F0450-42	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0287	0.015 AL	0.0010	mg/L		07/13/21 1513	07/13/21 1928	LLW

Client Sample ID: CSHSMS - 45	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:53
Lab Sample ID: S1F0450-43	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0612	0.015 AL	0.0010	mg/L		07/13/21 1513	07/13/21 1930	LLW

Client Sample ID: CSHSMS - 46	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 5:41
Lab Sample ID: S1F0450-44	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		07/13/21 1513	07/13/21 1935	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S1F0450

Client Sample ID: CSHSMS - 47	Collected By: Alex Frame
Sample Matrix: Drinking Water	Collection Date: 06/11/2021 6:02
Lab Sample ID: S1F0450-45	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		07/13/21 1513	07/13/21 1937	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- MDL: Minimum Detection Limit
- mg/L: Milligrams per Liter
- NYVOA: New York DOH Part 5 Public Water System MCLs
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Renee Lantz
Customer Relationship Specialist
Reported: 07/25/2021 18:53

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address
 Client Name: GST BOCES
 Address: 459 Philo Rd
 City, State, Zip: Elmira NY 14905
 Contact: Alex Frame
 Telephone No.: 607-739-3581 x 1476
 Send Report via: Mail e-mail (address) alex@gsiboces.org
 Project: 2021 10 NYCRR Subpart 67.4 Location: Campbell Savona HS/MS PO No.:
Invoice Address
 Client Name: Campbell Savona CSD
 Address: 8455 County RI 125
 City, State, Zip: Campbell NY 14821-9518
 Contact: John Machuga
 Telephone No.: 607-527-9800
 Send Invoice via: alex@gsiboces.org
Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 Report Type: Results Only Level 1 Level 2 Level 3 Level 4 EDD
 Mail Fax e-mail (address) imachuga@cscsd.org
 Compliance Monitoring? Yes No
 () Agency/Program
 Sampler Signature: *Alex Frame* Sampler Phone No.: 607-739-3581 x 1476

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS



GST BOCES/Elmira
 PM: Renee Lantz

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Additional Notes
	CSHSMS-1	6/11/21	5:22	1	DW	G	W	Lead in DW
	CSHSMS-4		5:21					
	CSHSMS-5		5:25					
	CSHSMS-6		5:26					
	CSHSMS-7		5:26					
	CSHSMS-8		5:27					
	CSHSMS-9		5:28					
	CSHSMS-10		5:29					
	CSHSMS-11		5:30					
	CSHSMS-12		5:30					

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Comments

Relinquished By (signature) *[Signature]* Date/Time 6/11/21 8:05
 Relinquished By (signature) *[Signature]* Date/Time 6/11/21 8:05
 Received By (signature) *[Signature]* Date/Time 6/11/21 08:05
 Received By (signature) *[Signature]* Date/Time 6/11/21 08:05

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number


Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address: Client Name: GST BOCES Address: 459 Philo Rd City, State, Zip: Elmira NY 14905 Contact: Alex Frame Telephone No.: 607-739-3581 x 1476 Send Report via: [] Mail [x] Fax [] e-mail (address) **aframe@gstbores.org** Location: Campbell Savona HS/MS PO No.: 2021 10 NYCRR Subpart 67.4

Invoice Address: Client Name: Campbell Savona CSD Address: 8455 County RI 125 City, State, Zip: Campbell NY 14821-9518 Contact: John Machuga Telephone No.: 607-527-9800 Send Invoice via: [x] Mail [] Fax [x] e-mail (address) **imachuga@cscosd.org** Location: Campbell Savona HS/MS PO No.: 607-739-3581 x 1476

Turnaround Time: [x] Routine (5 to 7 business days) [] RUSH* (notify lab) Report Type: (needed by) Samples Received on Ice? Yes **No** N/A Custody Seals Intact? Yes **No** N/A Results Only [] Level 1 [] Level 2 [] Level 3 [] Level 4 [] EDD [x] Mail [] Fax [x] e-mail (address) **imachuga@cscosd.org** Compliance Monitoring? [x] Yes [] No () Agency/Program




Sampled by (PRINT): **Alex Frame** Signature:  Sampler Phone No.: 607-739-3581 x 1476




* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types
	CSHSMS-13	6/11/21	5:31	1	DW	G	N
	CSHSMS-14		5:31				
	CSHSMS-15		5:35				
	CSHSMS-16		5:35				
	CSHSMS-17		5:37				
	CSHSMS-18		5:19				
	CSHSMS-19		5:39				
	CSHSMS-20		5:39				
	CSHSMS-21		5:39				
	CSHSMS-22		5:08				

Possible Hazard Identification: [] Hazardous [] Non-Hazardous [] Radioactive [] Disposition as appropriate [] Return [] Archive

Comments: Relinquished By (signature)  Date/Time: 6/11/21 8:05
 Relinquished By (signature)  Date/Time: 6/11/21 8:05
 Relinquished By (signature)  Date/Time: 6/11/21 8:05

Received By (signature)  Date/Time: 6/11/21 8:05
 Received By (signature)  Date/Time: 6/11/21 8:05
 Received By (signature)  Date/Time: 6/11/21 8:05



CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number
Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address: GST BOCES, 459 Philo Rd, Elmira NY 14905, Alex Frame, 607-739-3581 x 1476, 2021 10 NYCRR Subpart 67.4

Client Name: GST BOCES, Address: 8455 County Rt 125, City, State, Zip: Campbell NY 14821-9518, Contact: John Machuga, Telephone No.: 607-527-9800, Send Report via: [] Mail [] Fax [X] e-mail (address) aframe@gstbooces.org Send Invoice via: [] Mail [] Fax [X] e-mail (address) jmachuga@cscsd.org

Invoice Address: Campbell Savona CSD, 8455 County Rt 125, Campbell NY 14821-9518, John Machuga, 607-527-9800

Turnaround Time: [X] Routine (5 to 7 business days), [] RUSH* (notify lab)

Temperature Upon Receipt (°C): Therm ID: Holding Time: Samples Received on Ice? Yes No [N/A]


Custody Seals Intact? Yes No [N/A]

Level 1 [] Level 2 [] Level 3 [] Level 4 [] EDD

Compliance Monitoring? [X] Yes [] No () Agency/Program

Sampler Phone No.: 607-739-3581 x 1476

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved



Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Sample Disposition	Date/Time
	CSHSMS-23	6/11/21	5:09	1	DW	G	MC	Dispose as appropriate	6/11/21
	CSHSMS-24		5:09						
	CSHSMS-25		5:09						
	CSHSMS-26		5:11						
	CSHSMS-27		5:12						
	CSHSMS-28		5:12						
	CSHSMS-29		5:12						
	CSHSMS-30		5:16						
	CSHSMS-31		5:14						
	CSHSMS-32		5:15						

Requested Analysis: **Lead in DW**

Relinquished By (signature): *[Signature]* Date/Time: 6/11/21

Received By (signature): *[Signature]* Date/Time: 6/11/21

Relinquished By (signature): *[Signature]* Date/Time: 6/11/21

Received By (signature): *[Signature]* Date/Time: 6/11/21

Relinquished By (signature): *[Signature]* Date/Time: 6/11/21

Received By (signature): *[Signature]* Date/Time: 6/11/21

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 i

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C)
 Therm ID

Client Name: GST BOCES
 Address: 459 Philo Rd
 City, State, Zip: Elmira NY 14905
 Contact: Alex Frame
 Telephone No.: 607-739-3581 x 1476

Lab Report Address
 Client Name: GST BOCES
 Address: 459 Philo Rd
 City, State, Zip: Elmira NY 14905
 Contact: Alex Frame
 Telephone No.: 607-739-3581 x 1476

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type
 Results Only
 Level 1
 Level 2
 Level 3
 Level 4
 EDD

Compliance Monitoring? Yes No

() Agency/Program

Send Report via: Mail e-mail (address)

Send Invoice via: Mail Fax e-mail (address)

Project: 2021 10 NYCRR Subpart 67.4

Location: Campbell Savona HS/MS

PO No.:

Sampler Signature: Alex Frame

Sampler Phone No.: 607-739-3581 x 1476

Matrix: DW

Grab / Comp: G

Date Collected: 6/14/21

Matrix Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Preservative Types: *Lead in DW*

No. of Containers: 1

Time Collected: 5:44, 5:44, 5:55, 5:56, 5:58, 5:57, 5:47, 5:48, 5:50

Requested Analysis

Sample Disposition: Dispose as appropriate Return Archive

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21

Relinquished By (signature): *[Signature]*

Date/Time: 6/11/21



GST BOCES/Elmira
 PM: Renee Lantz

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address: GST BOCES, 459 Philo Rd, Elmira NY 14905, Alex Frame, 607-739-3581 x 1476, 2021 10 NYCRR Subpart 67.4

Invoice Address: Client Name: Campbell Savona CSD, Address: 8455 County Rt 125, City, State, Zip: Campbell NY 14821-9518, Contact: John Machuga, Telephone No.: 607-527-9800, Send Invoice via: aframe@gstbooces.org, PO No.:

Turnaround Time: Routine (5 to 7 business days), RUSH* (notify lab) (needed by)

Temperature Upon Receipt (°C): Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Report Type: Results Only Level 1 Level 2 Level 3 Level 4 EDD

Compliance Monitoring? Yes No () Agency/Program: imachuga@cscsd.org

Sampler Phone No.: 607-739-3581 x 1476



Sampled by (PRINT): Alex Frame

Sampler Signature: [Signature]

Sampler Phone No.:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Additional
	CSHSMS-42	6/11/21	5:50	1	DW	g	MC	
	CSHSMS-43		5:51	1	DW	g	MC	
	CSHSMS-44		5:52	1	DW	g	MC	
	CSHSMS-45		5:53	1	DW	g	MC	
	CSHSMS-46		5:41	1	DW	g	MC	
	CSHSMS-47		6:02	1	DW	g	MC	

Requested Analysis

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive Dispose as appropriate Return Archive

Comments:

Relinquished By (signature): [Signature] Date/Time: 6/11/21 805

Received By (signature): [Signature] Date/Time: 6/11/21 085